



Do: <Tomasz.Lukaszewski@aniro.pl>
DW: <Roy_luo@sinexcel.com>,
UDW:
Temat: Re: PD: urgent technical inquiry
Od: Gabby Yang-Sinexcel Electric <gabby_yang@sinexcel.com> - poniedziałek 2019-10-07 14:59

Hi Tomasz,

The heat loss please check as below table. The data is about 3% of module power capacity.

	cabinet heat loss and Ventilation								
cabinet capacity	<100A	150A	200A	250A	300A	400A	500A	550A	600A
power loss (kw)	< 1.8	2.7	3.6	4.5	5.4	7.2	9	9.9	10.8
Forced air cooling(L/sec)	< 302	453	604	755	906	1208	1510	1661	1812

Regards

Gabby_yang

Business Development Manager

WhatsApp: +86-158-1442-0260

Cellphone: +86--158-1442-0260

<http://en.sinexcel.com>

